



NOTE:

CRUSHED STONE BEDDING SHALL BE ANGULAR 1/4 TO 3/4 INCHES GRADED STONE. LATEST REVISION OF ASTM C 33-GRADATION #67 (ASTM #67) OR #57 (ASTM #57) ARE ACCEPTABLE.



**CITY OF FAIRBURN, GEORGIA
PLASTIC PIPE BEDDING FOR
PVC AND HDPE PIPE MATERIALS**

DATE:
12/29/04
DETAIL NO.
P003