



NOTE:  
MANHOLE STEPS NOT  
SHOWN IN PROFILE.

4" DIP VENT PIPE  
W/ BUG SCREEN  
POURED IN PLACE  
CONCRETE SLAB SEE  
NOTE 4

6" DIAMETER (MINIMUM) PRE-CAST  
WET WELL BASE & SECTIONS

LOCATE VALVE VAULT  
IN UNDISTURBED EXCAVATION  
FROM WET WELL

- NOTES:**
1. PUMP STATIONS SHALL MEET ALL STATE MINIMUM DESIGN REQUIREMENTS AND BE APPROVED BY THE CITY ENGINEER.
  2. WET WELLS SHALL BE EPOXY COATED.
  3. ALL PIPE AND VALVE SIZES DISPLAYED ARE MINIMUM SIZES AND THE ACTUAL SIZES WILL BE DETERMINED BY THE HYDRAULIC DESIGN OF A PROFESSIONAL ENGINEER.
  4. PRECAST TOP SLAB MAY BE USED IF APPROVED BY CITY ENGINEER.

CITY OF FAIRBURN, GEORGIA  
WET WELL AND VALVE PIT  
PROFILE VIEW

DATE:  
09/27/07  
DETAIL NO.  
S016