



NOTES:

1. PUMP STATIONS SHALL MEET ALL STATE MINIMUM DESIGN REQUIREMENTS AND BE APPROVED BY THE CITY ENGINEER.
2. WET WELLS SHALL BE EPOXY COATED OR HAVE AN INTEGRAL LINER.
3. ALL PIPE AND VALVE SIZES DISPLAYED ARE MINIMUM SIZES AND THE ACTUAL SIZES WILL BE DETERMINED BY THE HYDRAULIC DESIGN OF A PROFESSIONAL ENGINEER.
4. PRECAST TOP SLAB MAY BE USED IF APPROVED BY CITY ENGINEER.

CITY OF FAIRBURN, GEORGIA
WET WELL AND VALVE PIT
PLAN VIEW

DATE: 09/27/07
DETAIL NO. S015