



NOTES:

1. HYDRANT LUGS AND TIE RODS MAY BE USED IN LIEU OF CONCRETE REACTION BRACING AT CONTRACTOR'S OPTION.
2. PAINT HYDRANT IN ACCORDANCE W/AWWA C502 COLOR TO BE APPROVED BY ENGINEER.
3. EXACT LOCATION OF HYDRANTS TO BE DETERMINED IN FIELD BY ENGINEER & OWNER.



**CITY OF FAIRBURN, GEORGIA
FIRE HYDRANT ASSEMBLY**

DATE:
08/28/07
DETAIL NO.
W001