



NOTES:

1. FOR BACKFLOW PREVENTION DEVICE, PROVIDE 8" INTERNALLY LOADED DOUBLE CHECK VALVE ASSEMBLY COMPLETE WITH OS&Y GATE VALVES AND BRONZE BODY BALL VALVE TEST COCKS FITTED WITH BRONZE PLUGS AND CONFORMING WITH AWWA C510 AND ASSE STD 1048.
2. PROVIDE CONCRETE SUPPORTS FOR PIPE & ASSEMBLY TO ELIMINATE ANY STRAIN ON ALL PIPE JOINTS.



CITY OF FAIRBURN, GEORGIA
FIRE MAIN & DOMESTIC
WATER CONNECTION & VAULT

DATE:
12/29/04
DETAIL NO.
W005