



NOTES:

1. FOR BACKFLOW PREVENTION DEVICE, PROVIDE 6" INTERNALLY LOADED DOUBLE CHECK VALVE. ASSEMBLY COMPLETE WITH NRS GATE VALVES AND BRONZE BODY BALL VALVE TEST COCKS FITTED WITH BRONZE PLUGS AND CONFORMING WITH AWWA C506, FCC C&HR 69-2 AND ASSE STD. 1015.



CITY OF FAIRBURN, GEORGIA
 TYPICAL 1 1/2" & LARGER
 SERVICE AND BACKFLOW PREVENTION ASSEMBLY

DATE:
 12/29/04
 DETAIL NO.
 W006