



CITY OF FAIRBURN

FIRE PREVENTION

56 SW Malone St. Fairburn Ga. 30213

Telephone (770) 964-2244

Fax (770) 969-3484

DAY CARE PRE-INSPECTION CHECKLIST

EXTERIOR OF BUILDING

- Combustibles store against building
- Building address posted and visible
- Walkways clear

GENERAL

- Were alterations made since last inspection
- Housekeeping maintained
- No exposed wiring
- Electrical junction boxes covered
- No storage in mechanical rooms
- Fire extinguishers present
- Fire extinguishers tagged and current
- Fire extinguishers mounted 18" – 5' from floor

LIFE SAFETY

- Occupant loads posted
- Exit enclosures free of storage
- Exit doors not blocked
- Exit doors open and close freely
- Exit signs working properly
- Panic hardware on door working
- Egress paths clear of obstructions
- Emergency lighting working properly

FIRE ALARM SYSTEM

- Fire alarm system present
- Annual test performed on alarm
- Any obstructions to pull stations

SPRINKLER SYSTEM

- Sprinkler system present
- Test papers at facility
- Annual inspection performed
- All deficiencies corrected
- Valves locked
- Storage no closer than 18" to sprinkler heads

OPERATING FEATURES

- Is there a written emergency plan
- Are emergency drills conducted
- Number of drills per school year
- Artwork and teaching materials on walls less than 20% of wall area
- Are there daily inspections of exits
- Is there a monthly fire inspection by trained staff

KITCHEN AREAS

- Is there a commercial hood system present
- Is there a hood cleaning tag present on front corner of hood
- Is the free from grease build up
- Are the filters clean from grease build up
- Is the grease collection pan present
- Is the hood extinguishment system tagged
- Is there proper nozzle coverage
- Are the caps on the nozzles
- Is the kitchen secure from children
- Is the fire extinguisher present in the kitchen